



### Code 6107 HYDROCHECK COLORTEST CHLORINE (DPD)

RANGE: A: 0,1 - 0,2 - 0,3 – 0,4 - 0,5 - 0,75 - 1,0 – 1,5 ppm Cl<sub>2</sub>  
 B: 0,025 - 0,05 - 0,075 ppm Cl<sub>2</sub>

NUMBER OF TEST: 350

#### KIT CONTAINS:

- 1 bottle reagent Chlorine A
- 1 bottle reagent Chlorine B
- 1 bottle reagent Chlorine C
- 2 test tubes 20cc with stopper
- 1 measuring syringe for sample
- 1 color comparator
- 1 color scale
- instructions

#### NOTES:

The method is recommended for polluted water, if the aim is to measure the free chlorine and the combined chlorine (chloramine).

To obtain a higher precision, the color comparator allows to compare the color between 2 test tubes containing the same water quantity.

HYDROCHECK allows very simple and quick test to a low price.

#### REFILLS:

refill spectratest chlorine

Code 6422

- 3 bottles reagent Chlorine A
- 3 bottles reagent Chlorine B
- 3 bottles reagent Chlorine C

test tube da 20cc, package 10

Code 3310