



Code N° 1007 IPT CARBONIC ACID (phenolphthalein alkalinity in french degrees)

SENSITIVITY: 0,5 french degrees (on 10 ml)

TEST QUANTITY: 625 french degrees

KIT CONTAINS:

- 1 bottle 25ml titrant Acidity
- 1 bottle 15ml indicator P
- 1 test tube 20ml
- use directions

NOTES:

For higher precision we recommend the HYDROCHECK kits.

SPARE PARTS:

- titrant acidity, 6 bottles 25ml
- titrant acidity, 6 bottles 250ml
- indicator, 6 bottles 15ml
- 10 test tube 20ml,

Code N° 3105
Code N° 3106
Code N° 3004
Code N° 3310

INTERFERENCE:

Water colors such as to prevent the appreciation of the color changes of the indicators.

Low water temperatures slow down the color change of the indicator.

The recommended temperature for the analysis is between 20 and 30 ° C.