

IPT SULFITE

Directions for use

1. Rinse the measuring vessel with the water to be tested and fill to the 5 ml mark.
2. Add 2 drops of reagent A and swirl.
3. Add 2 drops of reagent B and swirl.
4. Add titrant drop by drop mixing after each addition. Count the drops to the appearance of a blue colour. According to the Titrant used, in a 5 ml sample each drop corresponds to the value indicated on the bottle.